

RECOMMENDED SPECIFICATION FOR PREPARATION OF GYPSUM BOARD SURFACES PRIOR TO TEXTURE

1. SCOPE

Unless otherwise indicated, all walls, partitions, and ceilings on which gypsum board has been applied, and to which a texture is to be added, are included.

- 1.1 This recommended specification covers the preparation of gypsum board prior to application of texture materials by various methods such as spray, roller, brush, trowel, etc.
 - 1.2 All materials to be used in accordance with all codes, specifications and manufacturers recommendations.
 - 1.3 Gypsum board finish shall be completed to the desired or specified level of finish prior to preparation for texture application.
-

2. JOB CONDITIONS

No materials shall be applied until a minimum temperature of 50°F (10 °C) has been maintained for a period of at least 48 hours in the working area and the surface moisture has been stabilized (dry).

The stated minimum temperature, along with adequate ventilation shall be maintained throughout the texture preparation and texture application process, and until all materials are dry and stable.

Unvented gas and oil heaters shall not be used.

3. MATERIALS AND SURFACE PREPARATION

3.1 For texture surfaces intended as final decorative finish.


3.1.1 Prior to texture application, entire board surface to be treated to minimize water soluble discoloring agents from leaching to the surface, and to minimize absorption differential by using one of two recommended procedures:

- (a) Apply a moisture barrier sealer with a perm rating of 1 or less to the board surface. This product must be compatible with, and provide a bondable surface for the texture materials to be used.
- (b) Apply a product recommended by the texture or paint manufacturers for this purpose.

3.2 For texture surfaces to be painted.

3.2.1 Prior to texture application, treat entire board surface to minimize absorption differential by using one of three recommended procedures:

- (a) Apply a thin skim coat of gypsum board joint compound to the entire surface as defined by GA-214 Recommended Levels of Finish for Gypsum Board, Glass Mat and Fiber-Reinforced Gypsum Panels.
- (2) Apply a coat of material specifically formulated for this purpose over the entire surface.
- (3) Apply a product recommended by the texture or paint manufacturer for this purpose. Allow to dry thoroughly before texture application.



4. TEXTURES APPLICATION

Texture materials are to be mixed and applied in accordance with manufacturer's recommendations.

Members

CertainTeed Gypsum • Continental Building products • Freeman Products • Magnum Products • National Gypsum Company • Panel Rey SA • Sherwin-Williams Company • Solid Products, Inc. • Southern Wall Products • Trim-Tex, Inc. • United States Gypsum Company • Westpac Materials

Associate Members

Active Minerals International • Akzo Nobel Cellulosic Specialties • ACG Materials • American Gypsum Company • Ames Taping Tools Company • Ashland • Canadian Gypsum Company • Celanese • Chemstar Products • Columbia Taping Tools • Dow Construction Chemicals • Evans Adhesives • HB Fuller • Henry Company • Lonza • P.T. Hutchins Company • SE Tylose USA • Tate & Lyle Ingredients Americas • Wacker Chemical Corporation

Honorary Members

Association of Wall and Ceiling Industries (AWCI) • Finishing Contractors Association, Intl (FCA) • Gypsum Association (GA) • Northwest Wall and Ceiling Bureau (NWCB) • Painting and Decorating Contractors of America (PDCA) • Technical Services Information Bureau (TSIB) • Wall & Ceiling Bureau (WCB)